

**TABELA REGULACYJNA TEMPERATURY WODY INSTALACYJNEJ PO
STRONIE INSTALACJI NISKICH PARAMETRÓW**

Temperatura otoczenia	Temperatura zasilania
10	40
9	41
8	42
7	44
6	46
5	48
4	50
3	50
2	54
1	54
0	57
-1	59
-2	60
-3	61
-4	62
-5	64
-6	65
-7	67
-8	71
-9	72
-10	74
-11	76
-12	78
-13	80
-14	81
-15	82
-16	84
-17	85
-18	86
-19	87
-20	88
-21	89
-22	90
-23	90
-24	90
-25	90